



NOTES:

1. REFER TO FASTENING REQUIREMENTS ON PAGE 23 FOR APPROVED DECK TYPES.

2. FASTENER PENETRATION MINIMUMS:

WOOD PLANK:	1" PENETRATION INTO DECK
PLYWOOD:	1/2" THROUGH DECK
METAL:	3/4" THROUGH DECK (UPPER FLANGE ONLY)
STRUCTURAL CONCRETE:	1" PENETRATION INTO DECK

3. ATLAS RECOMMENDS THAT THE DESIGNER CONSIDER CAREFULLY THE NEED FOR A VAPOR/AIR RETARDER IN ORDER TO LIMIT MOISTURE/AIR FLOW INTO THE SYSTEM. DETERMINING THE NEED FOR AND LOCATION OF THE VAPOR/AIR RETARDER REMAINS SOLELY THE RESPONSIBILITY OF THE ARCHITECT, ENGINEER OR DESIGN PROFESSIONAL.

4. FOR TILE, SLATE, OR OTHER HEAVY ROOF COVERING, THICKER OSB, SUCH AS 3/4", MAY BE REQUIRED. CONSULT ROOF COVERING MANUFACTURER FOR RECOMMENDATIONS.